

Mecklenburg County Common Code Defects

Electrical

Code Defects

Support Boxes Properly

Code Description

110.13 Mounting and Cooling of Equipment.

(A) Mounting. Electrical equipment shall be firmly secured to the surface on which it is mounted. Wooden plugs driven into holes in masonry, concrete, plaster, or similar materials shall not be used.

Disclaimer: There may be other ways to comply with the Code. If so, you are not required to use this method to comply with the Code. You may want to investigate other options, or consult with a design professional identifying an equally code compliant solution.

End Notes

National Electrical Code

National Electrical Code Committee and National Fire Protection Association Inc.

Anaheim, CA August 2, 2001